



Building & DIY Products You Can Trust

Site 41, Knowsthorpe Way,

Cross Green Industrial Estate, Leeds, LS9 0SW

Telephone: +44 (0) 113 240 3456 Sales: +44 (0) 113 240 2424

Fax: +44 (0) 113 240 0024

e-mail: info@everbuild.co.uk

website: www.everbuild.co.uk

CONSTRUCTION PRODUCTS REGULATION

DECLARATION OF PERFORMANCE

No: 1121-CPR-JA5018

| | |
|--|---|
| 1. Identification Code | FIRE SEALANT 400 Codes: 400 BK / GY / WE |
| 2. Type, Batch and/or Serial Number | - For batch number - see packaging |
| 3. Intended use | Fire Stopping and Sealing Product for Linear Joint and Gap Seals, see ETA 13/1059 |
| 4. Manufacturer | Everbuild Building Products Ltd, Site 41, Cross Green Industrial Estate, Knowsthorpe Way, Leeds, LS9 0SW |
| 5. Authorised Representative | Not Applicable |
| 6. Assessment and Verification of Constancy of Performance | System 1 |
| 7. Notified Body and Tasks | Exova Warringtonfire 1104 |
| 8. European Technical Assessment | Exova Warringtonfire issued European Technical Approval ETA 13/1059 on the basis of ETAG 026, edition 2011, used as European Assessment Document (EAD) |
| 9. Declared Performance | TO ETAG 026 Edition 2011 |
| Reaction to Fire | Class E |
| Resistance to Fire | Resistance to fire performance and field application in accordance with En 13501-2. See ETA 13/1059 |



Building & DIY Products You Can Trust

Site 41, Knowsthorpe Way,

Cross Green Industrial Estate, Leeds, LS9 0SW

Telephone: +44 (0) 113 240 3456 Sales: +44 (0) 113 240 2424

Fax: +44 (0) 113 240 0024

e-mail: info@everbuild.co.uk

website: www.everbuild.co.uk

| | |
|-------------------------------|---|
| Air Permeability | Tested according to EN1314-1 see ETA 13/1059 |
| Dangerous Substances | See Clause 2.5 |
| Airborne sound insulation | Rw(C;Ctr) = 38 (-2;-9) |
| Durability and serviceability | Z₁ |
| Movement Capability | According to ISO 11600 F25LM |

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9 . The declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed: I. G. Southerington – Head of Technical

P.R. Thomas – Technical Manager

Dated: Leeds, 1/4/14