



Building & DIY Products You Can Trust

Site 41, Knowsthorpe Way,

Cross Green Industrial Estate, Leeds, LS9 0SW

Telephone: +44 (0) 113 240 3456 Sales: +44 (0) 113 240 2424

Fax: +44 (0) 113 240 0024

e-mail: info@everbuild.co.uk

website: www.everbuild.co.uk

CONSTRUCTION PRODUCTS REGULATION

DECLARATION OF PERFORMANCE

No: 1121-CPR-JA5019

1. Identification Code	FIRE SEALANT 300 Codes: 300 GY / WE
2. Type, Batch and/or Serial Number	- For batch number - see packaging
3. Intended use	Fire Stopping and Sealing Product for Linear Joint and Gap Seals, see ETA 13/1058
4. Manufacturer	Everbuild Building Products Ltd, Site 41, Cross Green Industrial Estate, Knowsthorpe Way, Leeds, LS9 0SW
5. Authorised Representative	Not Applicable
6. Assessment and Verification of Constancy of Performance	System 1
7. Notified Body and Tasks	Exova Warringtonfire 1104
8. European Technical Assessment	Exova Warringtonfire issued European Technical Approval ETA 13/1058 on the basis of ETAG 026, edition 2011, used as European Assessment Document (EAD)
9. Declared Performance	TO ETAG 026 Edition 2011
Reaction to Fire	Class E
Resistance to Fire	Resistance to fire performance and field application in accordance with En 13501-2. See ETA 13/1058



Site 41, Knowsthorpe Way,
Cross Green Industrial Estate, Leeds, LS9 0SW
Telephone: +44 (0) 113 240 3456 Sales: +44 (0) 113 240 2424
Fax: +44 (0) 113 240 0024
e-mail: info@everbuild.co.uk
website: www.everbuild.co.uk

Air Permeability	Tested according to EN1314-1 see ETA 13/1058
Dangerous Substances	See Clause 2.5
Airborne sound insulation	$R_w(C;Ctr) = 38 (-2;7)$
Durability and serviceability	Z₁
Movement Capability	According to ISO 11600 F12.5P

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9 . The declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed: I. G. Southerington – Head of Technical

P.R. Thomas – Technical Manager

Dated: Leeds, 1/4/14